

Monthly Exit and Emergency Light Log

Company Name: _____

Year: _____

	Location	1	2	3	4	5	6	7	8	9	10	11	Annual	Comments
1														
2														
3														
4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														
22														
23														
24														
25														

**All exit lighting shall be tested for 20 seconds each month and 1 hour annually.*